

Boothbay Region Elementary School

Cells with gray background represent original sample and followup sample

Sample Collected DATE	Sample #	Room	Location	ANALYSIS Date	Result (ug/L)	Above or Below EPA Standard (20 ug/L)
3/25/17	A/L labs	Hall	Bubbler by Kitchen	3/29/17	1	BELOW
4/2/17	1702917-01	Hall	Bubbler by Kitchen	4/4/17	< 0.5	BELOW
4/2/17	1702917-02	Shop	Southwall Left #1	4/4/17	22	ABOVE
4/2/17	1702917-03	Shop	Southwall Right #2	4/4/17	14	BELOW
4/2/17	1702917-04	Room 237	Sink	4/4/17	1.3	BELOW
4/2/17	1702917-05	Room 235	Sink	4/4/17	63	ABOVE
4/2/17	1702917-06	Hall	Bubbler by room 233	4/4/17	1.7	BELOW
4/2/17	1702917-07	Hall	Bubbler by Room 217	4/4/17	0.59	BELOW
4/2/17	1702936-01	Room 110	Bathroom	4/4/17	20	ABOVE
4/2/17	1702936-02	Room 110	Classroom sink	4/4/17	33	ABOVE
4/2/17	1702936-03	Room 110	Classroom Bubbler	4/4/17	110	ABOVE
4/2/17	1702936-04	Room 109	Bathroom	4/4/17	19	BELOW
4/2/17	1702936-05	Room 109	Classroom sink	4/4/17	43	ABOVE
4/2/17	1702936-06	Room 109	Classroom Bubbler	4/4/17	47	ABOVE
4/2/17	1702936-07	Room 108	Bathroom	4/4/17	17	BELOW
4/2/17	1702936-08	Room 108	Classroom sink	4/4/17	840	ABOVE
4/2/17	1702936-09	Room 108	Classroom Bubbler	4/4/17	36	ABOVE
4/2/17	1702936-10	Room 107	Bathroom	4/4/17	82	ABOVE
4/2/17	1702937-01	Nurses Room	Sink	4/4/17	5.3	BELOW
3/25/17	AL Labs	Home Ec. Room	Sink #1	3/29/17	20.7	ABOVE
4/2/17	1702937-02	Home Ec. Room	Sink #1	4/4/17	13	BELOW
4/2/17	1702937-03	Home Ec. Room	Sink #2	4/4/17	12	BELOW
4/2/17	1702937-04	Home Ec. Room	Sink #3	4/4/17	11	BELOW
4/2/17	1702937-05	Home Ec. Room	Sink #4	4/4/17	92	ABOVE
4/2/17	1702937-06	Home Ec. Room	Sink #5	4/4/17	34	ABOVE

Boothbay Region Elementary School

Cells with gray background represent original sample and followup sample

Sample Collected DATE	Sample #	Room	Location	ANALYSIS Date	Result (ug/L)	Above or Below EPA Standard (20 ug/L)
4/2/17	1702937-07	Home Ec. Room	Sink #6	4/4/17	5.2	BELOW
4/2/17	1702937-08	Room 113	Sink #1	4/4/17	81	ABOVE
4/2/17	1702937-09	Room 113	Sink #2	4/4/17	6.3	BELOW
4/2/17	1702937-10	Art Room	Sink #1	4/4/17	19	BELOW
4/2/17	1702938-01	Art Room	Sink #2	4/4/17	110	ABOVE
4/2/17	1702938-02	Art Room	Sink #3	4/4/17	2.9	BELOW
4/2/17	1702938-03	Art Room	Sink #4	4/4/17	1	BELOW
4/2/17	1702938-04	Hall	Bubbler by Art Room	4/4/17	3	BELOW
3/25/17	AL Labs	Room 225	Tch Room Sink	3/29/17	10	BELOW
4/2/17	1702938-05	Room 225	Tch Room Sink	4/4/17	<0.5	BELOW
3/25/17	AL Labs	Hall	Bubbler by Room 217	3/29/17	10	BELOW
4/2/17	1702938-06	Hall	Bubbler by Room 217	4/4/17	Missing Data	
4/2/17	1702938-07	Room 226	Sink	4/4/17	45	ABOVE
3/25/17	AL Labs	Room 228	Sink	3/29/17	38.9	ABOVE
4/2/17	1702938-08	Room 228	Sink	4/4/17	31	ABOVE
4/2/17	1702938-09	Room 228A	Sink #1	4/4/17	3.1	BELOW
4/2/17	1702938-10	Room 228A	Sink #2	4/4/17	12	BELOW
4/2/17	1702939-01	Room 107	Classroom sink	4/4/17	8	BELOW
4/2/17	1702939-02	Room 107	Classroom Bubbler	4/4/17	34	ABOVE
4/2/17	1702939-03	Room 106	Bathroom	4/4/17	6.9	BELOW
4/2/17	1702939-04	Room 106	Classroom sink	4/4/17	1100	ABOVE
4/2/17	1702939-05	Room 106	Classroom Bubbler	4/4/17	6.8	BELOW
4/2/17	1702939-06	Room 105	Bathroom	4/4/17	16	BELOW
4/2/17	1702939-07	Room 105	Classroom sink	4/4/17	10	BELOW
3/25/17	AL Labs	Room 105	Classroom Bubbler	3/29/17	16.4	BELOW

Boothbay Region Elementary School

Cells with gray background represent original sample and followup sample

Sample Collected DATE	Sample #	Room	Location	ANALYSIS Date	Result (ug/L)	Above or Below EPA Standard (20 ug/L)
4/2/17	1702939-08	Room 105	Classroom Bubbler	4/4/17	15	BELOW
4/2/17	1702939-09	Room 104	Bathroom	4/4/17	29	ABOVE
4/2/17	1702939-10	Room 104	Classroom sink	4/4/17	51	ABOVE
4/2/17	1702944-01	Boys Locker Rm	Sink	4/4/17	11	BELOW
4/2/17	1702944-02	Girls Locker Rm	Sink	4/4/17	5.4	BELOW
4/2/17	1702944-03	Gym	Bubbler West Side	4/4/17	2.9	BELOW
3/25/17	AL Labs	Gym	Bubbler East Side	3/29/17	13	BELOW
4/2/17	1702944-04	Gym	Bubbler East Side	4/4/17	<0.5	BELOW
3/25/17	AL Labs	Kitchen	Center Sink #1	3/29/17	17.6	BELOW
4/2/17	1702944-05	Kitchen	Center Sink #1	4/4/17	8.1	BELOW
4/2/17	1702944-06	Kitchen	Steam Kettle #2	4/4/17	28	ABOVE
4/2/17	1702944-07	Kitchen	Sink West Wall #3	4/4/17	1.6	BELOW
4/2/17	1702944-08	Kitchen	Sink West Wall #4	4/4/17	18	BELOW
4/2/17	1702944-09	Kitchen	Pedal Sink #5	4/4/17	23	ABOVE
4/2/17	1702944-10	Kitchen	Bathroom Sink	4/4/17	6.3	BELOW
4/2/17	1702947-01	Room 104	Classroom Bubbler	4/5/17	29	ABOVE
4/2/17	1702947-02	Room 103	Classroom sink	4/5/17	11	BELOW
4/2/17	1702947-03	Room 102	Bathroom Sink	4/5/17	19	BELOW
4/2/17	1702947-04	Room 102	Classroom sink	4/5/17	12	BELOW
4/2/17	1702947-05	Room 102	Classroom Bubbler	4/5/17	4.2	BELOW
4/2/17	1702947-06	Room 101	Bathroom Sink	4/5/17	23	ABOVE
4/2/17	1702947-07	Room 101	Classroom sink	4/5/17	18	BELOW
4/2/17	1702947-08	Room 101	Classroom Bubbler	4/5/17	30	ABOVE
3/25/17	AL Labs	Hall Admin Wing	Bubbler	3/29/17	13	BELOW
4/2/17	1702947-09	Hall Admin Wing	Bubbler	4/5/17	0.6	BELOW

Boothbay Region High School

Cells with gray background represent original sample and followup sample

Sample Collected DATE	Sample #	Room	Location	ANALYSIS Date	Result (ug/L)	Above or Below EPA Standard (20 ug/L)
3/25/17	AL Labs	Boys Bathroom	#199 #2 sink	3/29/17	3.6	BELOW
4/2/17	1702917-08	Boys Bathroom	#199 #2 sink	4/4/17	2.6	BELOW
3/25/17	AL Labs	Hall	Bubbler by room 207	3/29/17	2.1	BELOW
4/2/17	1702917-09	Hall	Bubbler by room 207	4/4/17	4.2	BELOW
4/2/17	1702917-10	Girls Restroom (200)	Sink #1	4/4/17	<0.5	BELOW
3/25/17	AL Labs	Kitchen	Sink #1	3/29/17	3.8	BELOW
4/2/17	1702940-01	Kitchen	Sink #1	4/4/17	3.4	BELOW
4/2/17	1702940-02	Kitchen	Sink #2	4/4/17	2.9	BELOW
4/2/17	1702940-03	Rejected Sample		4/4/17		
3/25/17	AL Labs	Room 12 (vis. Locker)	Sink	3/29/17	230	ABOVE
4/2/17	1702940-04	Room 12 (vis. Locker)	Sink	4/4/17	120	ABOVE
3/25/17	AL Labs	Hall	Bubbler by art Room	3/29/17	1	BELOW
4/2/17	1702940-05	Hall	Bubbler by art Room	4/4/17	0.82	BELOW
4/2/17	1702940-06	Art Room (9)	Sink #1	4/4/17	0.94	BELOW
4/2/17	1702940-07	Art Room (9)	Sink #2	4/4/17	1.5	BELOW
4/2/17	1702940-08	Art Room (9)	Sink #3	4/4/17	0.65	BELOW
4/2/17	1702940-09	Art Room (9)	SINK #4	4/4/17	<0.5	BELOW
4/2/17	1702940-10	Art Room (9)	Sink #5	4/4/17	1.2	BELOW
4/2/17	1702941-01	Boys Locker (100)	Sink #2	4/4/17	1.1	BELOW
4/2/17	1702941-02	Girls Locker (101)	Sink #1	4/4/17	<0.5	BELOW
4/2/17	1702941-03	Girls Locker (101)	Sink #2	4/4/17	1.9	BELOW
4/2/17	1702941-04	Girls Locker (101)	Sink #3	4/4/17	4.2	BELOW
4/2/17	1702941-05	Wood Shop (7)	Sink #1	4/4/17	12	BELOW
4/2/17	1702941-06	Wood Shop (7)	Sink #2	4/4/17	29	ABOVE
4/2/17	1702941-07	Room 8 Stem	Sink #1	4/4/17	48	ABOVE

Boothbay Region High School

Cells with gray background represent original sample and followup sample

Sample Collected DATE	Sample #	Room	Location	ANALYSIS Date	Result (ug/L)	Above or Below EPA Standard (20 ug/L)
4/2/17	1702941-08	Room 8 Stem	Sink #2	4/4/17	11	BELOW
4/2/17	1702941-09	Room 15 Dionne	Sink	4/4/17	120	ABOVE
4/2/17	1702941-10	Room 14 Officials Show.	Sink	4/4/17	8.7	BELOW
3/25/17	AL Labs	Girls Restroom (200)	Sink #2	3/29/17	2.2	BELOW
4/2/17	1702942-01	Girls Restroom (200)	Sink #2	4/4/17	8.7	BELOW
4/2/17	1702942-02	Girls Restroom (200)	Sink #3	4/4/17	2.1	BELOW
4/2/17	1702942-03	Staff Restroom (216)	Sink	4/4/17	1	BELOW
4/2/17	1702942-04	Exam Room (215A)	Sink	4/4/17	6.9	BELOW
4/2/17	1702942-05	Room 104	Sink #1	4/4/17	47	ABOVE
4/2/17	1702942-06	Room 104	Sink #2	4/4/17	19	BELOW
4/2/17	1702942-07	Room 104	Sink #3	4/4/17	28	ABOVE
4/2/17	1702942-08	Room 104	Sink #4	4/4/17	11	BELOW
3/25/17	AL Labs	Admin Wing	Bubbler	3/29/17	1.2	BELOW
4/2/17	1702942-09	Room 104	Sink #5	4/4/17	37	ABOVE
4/2/17	1702942-10	Room 104	Sink #6	4/4/17	25	ABOVE
4/2/17	1702943-01	Room 103	Sink #3	4/4/17	20	ABOVE
4/2/17	1702943-02	Room 103	SINK #4	4/4/17	14	BELOW
4/2/17	1702943-03	Room 103	Sink #5	4/4/17	15	BELOW
4/2/17	1702943-04	Room 103	Sink #6	4/4/17	22	ABOVE
4/2/17	1702943-05	Room 103	Sink #7	4/4/17	15	BELOW
4/2/17	1702943-06	Room 103	Sink #8	4/4/17	32	ABOVE
4/2/17	1702943-07	Room 103	Sink #9	4/4/17	35	ABOVE
4/2/17	1702943-08	Room 105 (maybe 103?)	Sink #10	4/4/17	10	BELOW
4/2/17	1702943-09	Men's Restroom (100)	Sink #1	4/4/17	1.4	BELOW
4/2/17	1702943-10	Men's Restroom (100)	Sink #2	4/4/17	1.6	BELOW

